



The Chemours Company FC LLC
Titanium Technologies Florida Plant
5222 Treat Road, PO Box 753
Starke FL 32091

March 3, 2023

Mr. Chris Suarez
Mining and Mitigation Program
2600 Blair Stone Road, MS 3577
Tallahassee, FL 32399-2400

Via Email: chris.suarez@floridaDEP.gov

RE: The Chemours Company FC LLC
TRS Stormwater Pond 1 Release
Incident No. 2023-1701

Dear Mr. Suarez:

The following provides additional information pertaining to the discharge of process water/stormwater from Stormwater Pond 1 on February 26, 2023. Per the notification to the Department on February 26, 2022, a release of approximately 228,000 gallons occurred from Stormwater Pond 1.

The facility experienced a process upset, that exceeded the plant containment area. Process water entered the stormwater pond. All water was contained in the adjacent ditch system. An alum drip was placed at the ditch to settle out any solids. No sampling was initiated as the water was contained in the ditch permitted for impacts through the ERP.

The process water from the stormwater pond was pumped to the process pond. Solids will be removed from the stormwater pond and the area will be re-graded. A valve will be placed on the stormwater outlet pipe, so in the event of process upset, water can be contained in the stormwater pond and pumped to the process pond.

Should you have any questions regarding the attached, please do not hesitate to contact me at 904.263.8592.

Sincerely,

Connie Henderson
Environmental Manager

c: Herndon Sims, DEP NE District